



**Strojirenský zkušební ústav, s.p.,  
(Engineering Test Institute, Public Enterprise)  
Authorized Body 202  
Hudcova 424/56b, Medlánky, 621 00 Brno, Czech Republic**

Authorization Decision No. 3/2020 of 10 August 2020

issues

# TYPE CERTIFICATE

Number: **202-173-B-01277-22**

Manufacturer: Ampla a.s.  
Šafaříkova 1737  
539 01 Hlinsko  
Czech Republic

Company ID No: 28485408

Products: 1. Portable powder fire extinguisher HUSSECHUCK  
2. Portable powder fire extinguisher SHIELD

Type designation: 1. T162P6VSH, under constant pressure  
2. T162P6VSS, under constant pressure

Extinguishing performance rating: 34 A, 183 B, C  
Effective temperature range: -30°C to +60 °C  
Extinguishing agent: 6 kg – extinguishing powder Furex ABC Spezial

Place of manufacture: EMET Inovation s.r.o.  
Frenštátská 257  
739 11 Frýdlant nad Ostravicí  
Czech Republic

These products have been certified pursuant to provisions of Section 10 of Act 22/1997 Coll., on technical requirements for products and on amendment to certain Acts, as amended. The Authorized Body mentioned above hereby certifies that the characteristics of the samples of the products concerned have been found conforming to essential requirements pursuant to Government Regulation 173/1997 Coll., as amended.

In assessment of conformity, the authorised body has used the following applicable requirements:

ČSN EN 3-7+A1:2008, ČSN EN 3-8:2021, ČSN EN 3-10:2010.

The present Certificate has been issued on the basis of Final Report Final Report 30-16184/MZ of 2022-08-02.

The Certificate is valid **until 2027-08-31**, provided the holder does not violate the rules for using the Certificate.

This Certificate has been issued for the purpose of issuing the manufacturer's declaration of conformity of the products with the technical regulations mentioned above.

The rules for using the Certificate are specified on Page 2.

Brno, 2022-08-09



Ing. Tomáš Hruška  
Director

202-173-B-01277-22, Page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika  
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

[www.szutest.cz](http://www.szutest.cz)

verze 2



Fulfilment of the essential requirements pursuant to Government Regulation 173/1997 Coll., as amended, has been derived from the fulfilment of the requirements of the standards and technical regulations made use of, which are listed on Page 1 of this Certificate. Amendments to any of the normative documents made use of, especially amendments to standards or the issuance of new standards, may alter the facts under which the Certificate has been issued. In such a case, the applicability of the Certificate for the purpose of issuing the declaration of conformity for the product placed on the market must be reviewed.

#### RULES FOR USING THE CERTIFICATE

This Certificate may only be used as a certificate for the products specified on Page 1. This also applies to its use in advertising, promotional and commercial materials. This Certificate may be copied in its entirety without written consent of the Engineering Test Institute. Unauthorised or deceptive use of the Certificate may be sanctioned (Act 22/1997 Coll., on technical requirements for products and on the amendments to certain Acts, as amended).

It is prohibited to change, amend or overwrite the data contained in the Certificate.

The Certificate may not be used for the products changed without the consent of the Engineering Test Institute, Public Enterprise, in such a way that conformity with the applied standards and technical regulations has been affected.

The Certificate has been issued within the flexible scope of accreditation. The flexibly included standard is ČSN EN 3-8:2021.

The Manufacturer is still obliged to submit to supervision pursuant to Art.10 of ČSN EN 3-10:2010.

